


Note: DN100 connection required from Water Reference No. 122042022. Main Water to install Meter, Proposed 150mm watermain to be connected to above site after negotiation.



- NOTES:**
- LAYOUT IS ONLY INDICATIVE. FINAL POSITION OF SERVICES TO BE CONFIRMED ON SITE
 - ALL WORKS TO BE IN ACCORDANCE WITH IRISH WATER CODE OF PRACTICE
 - ALL WORKS TO BE IN ACCORDANCE WITH IRISH WATER STANDARD DETAILS
 - PROPOSED WATERMAIN LAYOUT FOR APARTMENT BLOCKS TO BE AGREED WITH MECHANICAL ENGINEERING CONSULTANT

DIMENSIONS

Figured dimensions only to be taken from this drawing. All dimensions to be checked on site. Architects to be informed immediately of any discrepancies before work proceeds.

COPYRIGHT

This drawing and any design hereon is copy/right of JOR Consulting Engineers and must not be reproduced in whole or in part without their express written consent.

- LEGEND**
- Existing Watermain
 - Existing Phase 1 & 2 Watermain
 - Proposed SHD Watermain
 - Proposed SHD Watermain to be slung from basement roof slab
 - Proposed Basement outline
 - Existing Hydrant
 - Proposed Hydrant
 - Proposed Sluice Valve
 - Existing Sluice Valve
 - Proposed Meter

REV	DATE	DETAILS
A	08/02/20	Issued for SHD planning application
B	29/06/20	Re-assued for SHD planning application

CLIENT	SCANRON LTD
PROJECT	DANESWELL PLACE BOTANIC ROAD DUBLIN
TITLE	PROPOSED WATERMAIN LAYOUT FOR SHD DEVELOPMENT
SCALE	N.T.S.
DATE CREATED	JUNE 20
DRAWN BY:	DOB
CHECKED BY:	MS
JOB No.	17-117
DRAWING No.	012
REV	B